



BP LABORATORY
 BP ROAD
 MONTAGUE GARDENS

LABORATORY REPORT

TEL. NO (021) 408-3161
 FAX. NO (021) 551-1698

REQUESTED BY:

Peter Cock

Sample No.	Date Taken	Product	Customer
1	13/09/2002	Diesel . U/ground tank & add.	Mr. L. Merafe - Gerniston
2	"	Diesel . U/ground tank	"

DATE RECEIVED: 27/09/2002	REPORT NO. 02/1618
ANALYSED BY: PM	ANALYSIS NO. TS/02/2780-2781

TEST	UNIT	1	2			
Free Water	% vol.	Nil	Nil			
Suspended Water	% vol.	Nil	Nil			
Sediment		Nil	Nil			
Density @ 20°C	Kg/L	0.8402	0.8403			
Flash Point(PMCC)	°C	66	68			
Colour (ASTM)	D1500	<2.0	<2.0			
Distillation: IBP	°C	187	188			
10 % vol. rec. \bar{a}	°C	224	227			
50 % vol. rec. \bar{a}	°C	282	284			
70 % vol. rec. \bar{a}	°C	308	309			
90 % vol. rec. \bar{a}	°C	345	346			
FBP	°C	371	375			
Res./Loss	% vol.	1.6/0.5	1.2/0.7			
Viscosity @ 40°C	cSt	3.4	3.3			

REMARKS:

Reported by :TPM

A C Roomaney

CHIEF CHEMIST

DATE: 01/10/2002